

Rotronic Modbus – Digital Communication

Modbus is a popular communication protocol used in industrial automation to exchange data between devices such as PLCs, sensors, and actuators. Modbus can be over Ethernet (known as Modbus TCP) using standard patch leads or over RS-485 and RS-232 (known as Modbus RTU) using twisted pair cables.

This guidance is intended for users who have not worked with Modbus and need a step-by-step instruction on how to connect the HCD-S-MOD (RMS-HCD-S & E2-05XX-MOD) to a computer and getting started with read out data through RS-485 with Modbus RTU protocol:

Delivery Package

- RMS-HCD-S
- E2-05XX-MOD

List of used materials

- RMS-HCD-S
- E2-05XX-MOD
- AC3001
- Luster terminal (3 pol)
- USB-RS485-WE-1800-BT
- Modbus Master software
- RMS-CONFIG
- Hex Converter



Why use Modbus over RS-485?

Modbus RTU networks are predominantly used due to the ease and reduced cost of adding many devices via a single “bus cable” (unlike analogue or ethernet that requires a direct cable to every device). With Modbus RTU networks you can also easily add additional devices at any point along the bus cable. Only a single PLC device is required to communicate with potentially up to 247 devices presenting a huge cost saving compared to analog signals. Finally, by using digital vs analog there is no signal degradation or error and you are also able to receive additional information such as device and probe serial numbers, units & error codes.


Interface

Per default the RMS-HCD-S has an UART service interface which is converted by the E2-05XX-MODBUS into RS-485. The third-party device US-RS485-WE-1800-BT so then convert the RS-485 signal to USB:

Device	Interface				Communication		Parameter	Cost
	Analog	Digital	+AC3001	+E2-05XX-MOD ¹	Modbus		Hum/Temp	Budget
RMS-HCD-S	No	UART	USB	RS-485	Yes	RTU	%rh & °C	\$\$

¹ Note: Rotronic can only support the RMS-HCD-S in combination with the cable E2-05XX-MOD in use.


Schematic structure



Wiring


Wiring of the setup

1. Connect the RMS-HCD-S with the E2-05XX-MOD
2. Connect the E2-05XX-MOD with the luster terminal
3. Connect the USB-RS485-WE-1800-BT with the luster terminal
4. Connect the USB-RS485-WE-1800-BT with the USB to computer



Specification

1. RMS-HCD-S




2. E2-05XX-MOD

Specifications		
Supply voltage to adapter		5...28 VDC
Supply voltage to probe		3.3 VDC
Current consumption (includes HC2 probe)		10 mA typical
RS-485 specifications	Baud rate: 19'200 / Parity: none / Data bits: 8 / Stop bits: 1	



Electrical installation		
Green	VDD (+)	Power supply +
Grey	GND	Power and digital signal
Red	RXD	RS-485 bi-directional TX+ / RX+
Blue	TXD	RS-485 bi-directional TX- / RX-

3. USB-RS485-WE-1800-BT



Setup the Modbus address

Review the RMS-HCD-S Modbus address of the RMS-HCD-S probe with the RMS-CONFIG software. Plug the RMS-HCD-S into the AC3001 cable and add a local device, per default the probe address is 247:




Modbus Master software

Modbus Tool-Master


The Modbus Master software is a third-party software which we can use to start communication with the connected RMS-HCD-S. To communicate with the systems, the following information must be set up:

1. Modbus RTU
2. Baud rate 19'200
3. Parity: none
4. Data bits: 8
5. Stop bits: 1
6. Slave ID: 247





Port Name

Before the communication can be started, the port name must be determined. For this, you can check the ports within the Device-Manager on your local computer:



Connect the Modbus Master software



Read out data

The Modbus address overview can be reviewed here: [MODBUS](#)

The addresses 31000 and 31004 are the humidity & temperature values.

NOTE: RS485 address is the register address -1!

Add the start address 31000, Size 4, Display Format hex, press Apply and then Read Input register:


Register	Name	Description	Data type
31'001	Humidity	• Current humidity value (part 1)	Float 32
31'002		• Current humidity value (part 2)	Bit
31'003	Temperature	• Current temperature value (part 1)	Float 32
31'004		• Current temperature value (part 2)	Bit
31'005	Calculation	• Current calculation value (part 1)	Float 32
31'006		• Current calculation value (part 2)	Bit
31'007	Measurement flags Humidity	• Current measurement flags humidity	Int. 16bit
31'008	Measurement flags Temperature	• Current measurement flags temperature	Int. 16bit

Read Current Float Value (Registers 31'001 to 31'008)

Data received from system:

31000: 0xd2ce

31001: 0x5e42



Data format received

The data format, or also called swap mode. The standard setting is 0x0001 with target bytes d c b a:

Value	Swap Mode	Source Bytes	Target Bytes
0x0000	Big endian - No Swap	[a b] [c d]	[a b c d]
0x0001	Little endian - byte and word swap	[a b] [c d]	[d c b a]
0x0002	Mid-big endian - byte swap	[a b] [c d]	[b a d c]
0x0003	Mid-little endian - word swap	[a b] [c d]	[c d a b]

Address	Source Bytes	Target Bytes
31000	[a b] d2ce	[d c b a] 0x425ecd2
31001	[c d] 5e42	

Interpretation of received data

The received data in hex format must be converted into a float format with decimal values.

We use a third-party calculator which can be downloaded under [Floating Point to Hex Converter \(gregstoll.com\)](https://gregstoll.com/):

Register	Name	Description	Data type
31001	Humidity	Current humidity value (part 1)	Float 32 Bit
31002		Current humidity value (part 2)	

The hex value 0x425eced2 is in decimal floating data format 55.7 %rh.

Target Bytes

 0x425eced2

→

Target Bytes

 55.7 %rh

The screenshot shows the 'Floating Point to Hex Converter' interface. The 'Hex value' field contains '0x425eced2'. The 'Convert to float' button is clicked. The result shows the binary representation of the float, the sign (+1), the exponent (132), and the mantissa (1.10111101100111011010010). The final 'Float value' is 55.702.

Read out temperature values

The addresses 31003 and 31004 are the humidity values.

NOTE: RS485 address is the register address -1!

Add the start address 31002, Size 2, Display Format hex, press Apply **and then** Read Input register:

Register	Name	Description	Data type
31'001	Humidity	• Current humidity value (part 1)	Float 32 Bit
31'002		• Current humidity value (part 2)	
31'003	Temperature	• Current temperature value (part 1)	Float 32 Bit
31'004		• Current temperature value (part 2)	
31'005	Calculation	• Current calculation value (part 1)	Float 32 Bit
31'006		• Current calculation value (part 2)	
31'007	Measurement flags Humidity	• Current measurement flags humidity	Int. 16bit
31'008	Measurement flags Temperature	• Current measurement flags temperature	Int. 16bit

Read Current Float Value (Registers 31'001 to 31'008)

The screenshot shows the 'Modbus Master' configuration window. Under 'Communication', 'RTU' is selected. The 'Port' is 'COM5' and the 'IP Address' is '127.0.0.1'. Under 'Display Format', 'Hex' is selected. Under 'Functions', 'Read input register' is selected. The 'Start Address' is set to '31002' and the 'Size' is '2'. The 'Apply' button is highlighted.

Address	Source Bytes	Target Bytes
31002	[a b] 41bf	[d c b a] 0xea5cbf41
31003	[c d] 5cea	

The hex value 0xea5cbf41 is in decimal floating data format 23.9 °C

Target Bytes

0xea5cbf41

→

Target Bytes

23.9 °C

Floating Point to Hex Converter

☒ Show details ☒ Swap to use big-endian ☐ Uppercase letters in hex

Hex value: 0xea5cbf41 Convert to float

0x41bf5cea (swapped endianness)

4	1	b	f	5	c	e	a
0	1	0	0	0	0	1	0
1	0	1	1	1	1	0	1
0	1	0	1	0	1	1	0
0	1	0	0	0	0	1	1

sign exponent mantissa

+1 131 1.01111110101110011101010 (binary)

+1 * 2^{^(131 - 127)} * 1.4950230121612549

+1 * 16.0000000 * 1.4950230121612549

23.9204

Float value: 23.9204 Convert to hex

Change data format

Before we can change the data format, we must read out the actual byte-swap format.
The addresses 40001 show the actual byte-swap format:

NOTE: RS485 address is the register address -1!

Modbus Master

Communication: TCP Port 502, RTU Port Name COM5, Data Bits 8 Bits, Baud 19200, Stop Bits 1 Bit

Display Format: LED, Binary, Hex, Integer

Functions: Read coils, Read holding register, Write single coil, Write multiple coils, Read discrete, Read input register, Write single register, Write multiple register

Start Address 40001, Size 1

Apply Clear

Communication Log

>10:19:16: Connected using RTU to COM5

>10:19:21: TX: f7 03 9c 41 00 01 ee d8

>10:19:21: RX: f7 03 02 00 01 b1 91

>10:19:21: Read succeeded. Function code:3.

Value	Swap Mode	Source Bytes	Target Bytes
0x0000	Big endian - No Swap	[a b] [c d]	[a b c d]
0x0001	Little endian - byte and word swap	[a b] [c d]	[d c b a]
0x0002	Mid-big endian - byte swap	[a b] [c d]	[b a d c]
0x0003	Mid-little endian - word swap	[a b] [c d]	[c d a b]

Change to data format to 0x0000
Add the start address 40001, Size 1, Display Format hex, write into the address box a “0”, press Apply and then Write single register:

Modbus Master

Communication

Mode: TCP
Port: 502
IP Address: 127.0.0.1

RTU
Port Name: COM5
Baud: 19200
Data Bits: 8 Bits
Stop Bits: 1 Bit
Parity: None

Connect
Disconnect

Display Format

LED
Binary
Hex
Integer

Functions
Read coil
Read holding register
Write single coil
Write multiple coils
Read discrete
Read input register
Write single register
Write multiple register

Slave ID: 247
Import
Export

Start Address: 40001
Size: 1
Apply
Clear

40001 40002 40003 40004 40005 40006 40007 40008 40009 40010

Communication Log

>10:30:40: Connected using RTU to COM5
>10:30:45: TX: f7 06 9c 41 00 00 e3 18
>10:30:45: RX: f7 06 9c 41 00 00 e3 18
>10:30:45: Write succeeded: Function code:6

Read again the holding register of address 40001 and system has changed data format:

Communication Log

>10:30:40: Connected using RTU to COM5
>10:30:45: TX: f7 06 9c 41 00 00 e3 18
>10:30:45: RX: f7 06 9c 41 00 00 e3 18
>10:30:45: Write succeeded: Function code:6
>10:33:25: TX: f7 03 9c 41 00 01 ee d8
>10:33:25: RX: f7 03 02 00 00 40 51
>10:33:25: Read succeeded: Function code:3.

Value	Swap Mode	Source Bytes	Target Bytes
0x0000	Big endian - No Swap	[a b] [c d]	[a b c d]
0x0001	Little endian - byte and word swap	[a b] [c d]	[d c b a]
0x0002	Mid-big endian - byte swap	[a b] [c d]	[b a d c]
0x0003	Mid-little endian - word swap	[a b] [c d]	[c d a b]

Read out humidity values again

Address	Source Bytes	Target Bytes	Target Bytes
31002	[a b] c1f7	[d c b a] 0xc1f74c42	51.24 %rh
31003	[c d] 4c42		

ProcessSensing.com

8

Rotronic Modbus wall

The Rotronic test application includes all Rotronic devices that are Modbus RTU capable. The testing wall is designed in such a way, that the devices used are constantly evaluated. The transmission rate (error rate) can be tracked via the integrated monitor.



Rotronic Modbus application wall

Device list

- 2x PF4/PF5
- 3x HF5A-Digital
- 3x RMS-HCD-S
- 3x RMS-HCD-IC102
- 3x RMS-TCD-S-001

Modbus Master

- B&R X20CP1583 with RS-485 module X20IF1030

Bus cable

- VOLLTRON-Twist CY A 2X2X0,25

Rotronic Modbus wall

To ensure smooth communication between Modbus devices on a network, it is crucial that they all have the same communication parameters and unique Modbus device addresses. During initial setup each Rotronic device was programmed individually with a unique address. Rotronic Modbus protocol:

[Hardware Overview > Sensors and Probes > HCD-Sx > MODBUS \(rotronic.com\)](#)


The Modbus protocol utilizes function codes to exchange data between the master and slave devices and each vendor may have different register addresses for the same data due to the vendor-specific nature of Modbus registers. The Rotronic devices only support half-duplex operation, half-duplex is a communication mode which two devices can transmit and receive data, but not simultaneously. In other words, communication is bidirectional but can occur in one direction at a time. The SPS controller is the master and the Rotronic devices are the slaves. When the master requests, the first device can answer, then the second device, and so on.

Modbus cables can support different distances depending on the type of transmission and environment. The distance a Modbus cable can span without amplification depends on factors such as cable type, cable quality, transmission rate, voltage level, ambient temperature, and electromagnetic interference (EMI). For RS-485 Modbus communication using differential signal transmission, cable distances of up to 1200 meters can be achieved.



Up to 1200-meter cables

The dimensioning of terminating and bias resistors:



We have chosen 1 kΩ as bias resistors and 390 Ω respective 220 Ω AS terminating resistors.

Polling interval

The polling interval is defined by the slowest device in this case the PF4/PF5 with 400 ms. In this application we have 14 devices connected and one polling cycle takes approx. 5.6 seconds.

Polling cycle = Number of devices * Polling interval

Device	RMS-HCD-S	RMS-HCD-IC102	RMS-TCD-S-001	HF5A-D1D	PF4/PF5
Polling interval [ms]	250	250	250	250	400

Evaluation of the data

The Modbus wall is in continuous operation and is evaluated with an additional software. The wall simulates pressure changes several times a day, which is realized by a fan. Everyday some devices are switched off and turned on again. In addition, the Rotronic devices are continuously interrogated, and the response behavior is tracked and evaluated:

Out of more than 300'000 requests, only 8 responses were not received, which corresponds to an error rate of 0.002 %.

Slave ID	On/Off	Requests	Error	% Error	Dev. Type
Slave1	On	242749	9	0.000.00	PF4/5
Slave2	On	245151	0	0.000.00	PF4/5
Slave3	On	245151	0	0.000.00	HF5A
Slave4	On	245146	5	0.000.00	HF5A
Slave5	On	242753	8	0.000.00	HF5A
Slave6	On	245151	0	0.000.00	HCD
Slave7	On	245150	0	0.000.00	HCD
Slave8	On	242758	0	0.000.00	HCD
Slave9	On	245148	2	0.000.00	HCD-IC
Slave10	On	245149	1	0.000.00	HCD-IC
Slave11	On	242757	0	0.000.00	HCD-IC
Slave12	On	245150	0	0.000.00	TCD
Slave13	On	245150	0	0.000.00	TCD
Slave14	On	242755	0	0.000.00	TCD
Slave15	Off	0	0	0.000.00	
Slave16	Off	0	0	0.000.00	

Monitoring of all devices and values and error counting

Rotronic Modbus device list

Rotronic devices are designed to monitor and control various parameters, such as humidity, temperatures, and differential pressure. The new generation of probes and transmitters are capable to measure these parameters and a Modbus interface for communication with other devices on the network

Device	Interface				Communication		Parameter	Cost
	Analog	Digital	+AC3001	+E2-05XX-MOD	Modbus		Hum/Temp/Pressure	Budget
RMS-HCD-S	No	UART	USB	RS-485	Yes	RTU	%rh & °C	\$\$
RMS-HCD-IC	No	UART	USB	RS-485	Yes	RTU	%rh & °C	\$\$\$
RMS-TC-D-S	No	UART	USB	RS-485	Yes	RTU	°C	\$
PCD-S	No	UART	USB	RS-485	Yes	RTU	Pa	\$\$
HC2A-S	0...1V	UART	USB	RS-485	Yes	RO-ASCII	%rh & °C	\$\$
HC2A IC	0...1V	UART	USB	RS-485	Yes	RO-ASCII	%rh & °C	\$\$\$
PCMini52	0...1/5/10V	RS-485	No	No	Yes	RTU	%rh & °C	\$
PC62 & PC62V	0...1/5/10V	RS-485	No	No	Yes	RTU	%rh & °C	\$\$

Device	Probe Type	Interface screw-terminal		Interface LAN (RJ-45)	POE	Communication	Parameter	Cost
		Analog	Digital	Digital			Hum/Temp/Pressure	Budget
HF3	Fixed	Yes	No	No	No	No	%rh & °C	\$
HF5	Interchange	Yes	RS-485	Yes	No	RO-ASCII	%rh & °C	\$\$
PF4/PF5	Interchange	Yes	RS-485	Yes	Yes	RTU & TCP	%rh & °C & Pa	\$\$\$

Additional Guidance

For customers who do not have experience with digital communication, the Rotronic RMS online manual has additional pages with instructions on how to integrate the Rotronic device and start communication. For more detailed discussion please contact the Rotronic PM team.

[Help > Practical Topics > Understanding MODBUS > Guidance for MODBUS Communication with the RMS-HCD Digital Probe \(rotronic.com\)](#)

Conclusion

Customers increasingly seek the most cost effective and efficient solution. Digital communications can present many benefits to our customers. Understanding the basics of Modbus network is vital to support customers and their products.